


Certificate of Conformity

Certificate Number: CN-PVES-250009

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Shenzhen Growatt New Energy Co., Ltd. 4-13/F, Building A, Sino-German (Europe) Industrial Park, Hangcheng Ave, Bao'an District, Shenzhen, China
Product:	Hybrid Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	WIT 4K-HU, WIT 5K-HU, WIT 6K-HU, WIT 8K-HU, WIT 10K-HU, WIT 12K-HU, WIT 15K-HU
Brand Name<s>:	GROWATT
Product Complies with:	IEC/EN 62109-1: 2010 Safety of power converters for use in photovoltaic power systems Part 1: General requirements IEC/EN 62109-2: 2011 Safety of power converters for use in photovoltaic power systems Part 2: Particular requirements for inverters
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	240920051GZU-001, 06 January 2025 240920051GZU-002, 06 January 2025 240920051GZU-003, 06 January 2025

Additional information in Appendix.



Signature

Certification Manager: Grady Ye

Date: 10 January 2025



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250009

Model	WIT 4K-HU		WIT 5K-HU	WIT 6K-HU
PV Data				
Max. Input Voltage	1000 d.c.V			
PV Voltage Range	150~850 d.c.V			
Nominal input voltage	600 d.c.V			
Max. PV Input Current	40 d.c.A			
PV Isc	50 d.c.A			
Max. PV power	6.4 KW	8 KW	9.6 KW	
Number of MPP trackers	1			
Battery				
Battery Type	Lithium-ion/VRLA			
Battery Voltage Range	40-60 d.c.V	42-60 d.c.V		
Max. Charging and Discharging Current	110 d.c.A	125 d.c.A	150 d.c.A	
AC Data				
Nominal Voltage	3W/N/PE 230/400 a.c.V			
Nominal Frequency	50/60Hz			
Max. input/output power	8/4 kW	10/5 kW	12/6 kW	
Max. input/output apparent power	8.8/4.4 kVA	11/5.5 kVA	13.2/6.6 kVA	
Max. input/output Current	13.4/6.7 a.c.A	16.7/8.4 a.c.A	20/10 a.c.A	
Power factor	1.0 leading to 1.0 lagging			
Load Data				
Nominal Voltage	3W/N/PE 230/400 a.c.V			
Nominal Frequency	50/60Hz			
Max. output power	4 kW	5 kW	6 kW	
Max. output current	6.1 a.c.A	7.6 a.c.A	9.1 a.c.A	
Power factor	1.0 leading to 1.0 lagging			
GEN/Smart Load Data				
Nominal Voltage	3W/N/PE 230/400 a.c.V			
Nominal Frequency	50/60Hz			
Max. input/output power	8 kW	10 kW	12 kW	
Max. input/output current	12.1/12.1 a.c.A	15.2/15.2 a.c.A	18.2/18.2 a.c.A	
Power factor	1.0 leading to 1.0 lagging			
Others				
Ambient Temperature Range	-30°C ~ +60°C (>45°C Derating)			
Ingress protection rating	IP66			
Safety level	Class I			
Software version	TO 1.0			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250009

Model	WIT 8K-HU		WIT 10K-HU	WIT 12K-HU	WIT 15K-HU
PV Data					
Max. Input Voltage	1000 d.c.V				
PV Voltage Range	150~850 d.c.V				
Nominal input voltage	600 d.c.V				
PV Isc	25 d.c.A*2		25 d.c.A*3		
Max. PV Input Current	20 d.c.A*2		20 d.c.A*3		
Max. PV power	12.8 KW	16 KW	19.2 KW	24 KW	
Number of MPP trackers	2		3		
Battery					
Battery Type	Lithium-ion/VRLA				
Battery Voltage Range	42.6-60 d.c.V	48.4-60 d.c.V	51-60 d.c.V	55-60 d.c.V	
Max. Charging and Discharging Current	200 d.c.A	220 d.c.A	250 d.c.A	290 d.c.A	
AC Data					
Nominal Voltage	3W/N/PE 230/400 a.c.V				
Nominal Frequency	50/60Hz				
Max. input/output power	16/8 kW	20/10 kW	24/12 kW	30/15 kW	
Max. input/output apparent power	17.6/8.8 kVA	22/11 kVA	26.4/13.2 kVA	33/16.5 kVA	
Max. input/output Current	26.6/13.3 a.c.A	33.3/16.7 a.c.A	40/20 a.c.A	50.1/25 a.c.A	
Power factor	1.0 leading to 1.0 lagging				
Load Data					
Nominal Voltage	3W/N/PE 230/400 a.c.V				
Nominal Frequency	50/60Hz				
Max. output power	8 kW	10 kW	12 kW	15 kW	
Max. output current	12.1 a.c.A	15.2 a.c.A	18.2 a.c.A	22.7 a.c.A	
Power factor	1.0 leading to 1.0 lagging				
GEN/Smart Load Data					
Nominal Voltage	3W/N/PE 230/400 a.c.V				
Nominal Frequency	50/60Hz				
Max. input/output power	16 kW	20 kW	24 KW	30 KW	
Max. input/output current	24.2/24.2 a.c.A	30.3/30.3 a.c.A	36.4/36.4 a.c.A	45.4/45.4 a.c.A	
Power factor	1.0 leading to 1.0 lagging				
Others					
Ambient Temperature Range	-30°C ~ +60°C (>45°C Derating)				
Ingress protection rating	IP66				
Safety level	Class I				
Software version	TO 1.0				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.